


**IRP 2010 Draft 2, Public Hearings
November 2010**

Change happens – Stay in control


Arnaud Gouet

General Manager , Power Plants Southern Africa



Why is flexibility so important for the system?

- Intermediate load
 - Normal daily load variations due to consumer needs
 - Increase of wind and solar power introduce uncertainty which leads to sudden, large load variations
- Good intermediate plant
 - Fast start & stop, and restart
 - High efficiency: part load and high load
 - Good performance in hot and cold conditions – demand peaks take place at extreme temperatures
 - Competitive in BASELOAD



Wartsila in the USA



1000 MW of gas fired Wärtsilä power plants in the USA

- **Plant size range 50...200 MW**
- **Location in regional load centers**
- **Operation mode: Multitasking!**
 - First to start when wind calms down**
 - Base load on high tariff hours**
 - Peaking in the morning and evening**



Plains End, Colorado, USA


- Natural Gas, 113 MW, Intermediate/Peaking Plant based on spark ignition genset technology
- Located in Denver, Colorado area at 1875 Masl with performance guarantees based on ambient air temperature of 37 deg cel and the site elevation : 44 % efficeincy
- Has 20 X 18V34SG Gensets
- Commercial since May, 2002
- Provides superior ancillary services and other benefits
- No water Usage




18x 18V50DF, 300 MW Dual Fuel Power Plant Sangachal, Azeirbadjan



Operational flexibility vs. Energy efficiency



16x18V50SG SC and CC plant efficiency



Engine shaft
5% tolerance

Generator terminals
5% tolerance

Generator terminals
0% tolerance

Plant busbar MV-Side
0% tolerance
- Aux cons.

Plant interconnect HV-Side
0% tolerance
- Step up loss

SCGE
0-40°C Air
<200 masl
MN >90

49,9%
7214 kJ/kWh

48,6%
7407 kJ/kWh
pf = 0.8

46,2 %
7781 kJ/kWh
pf = 0.8

46,1 %
7815 kJ/kWh
Pf = 0.95

45,8 %
7854m kJ/kWh
pf = 1.0

Simple Cycle
Dry (Radiator cooled)

CCGE 315MW
25°C Air
<200 masl
MN>90
RH 30%

50,2 %
7171 kJ/kWh
Pf = 0.95

50.0 %
7200 kJ/kWh
pf = 1.0


Combi Cycle
Dry (Engines)
Cooling tower (CC)

Typical values for 16x18V50SG with one pressure combined cycle plant solution with 15 bar/340°C steam Engines with low noise radiator cooling (dry). CC with cooling tower.

Guarantee values are dependant on actual plant location, configuration and selected plant equipment



Start up and loading of a Gas Engine power plant compared to a GTCC

Only 10 minutes from start command to full load



Partial Load Performance

Comparing the Efficiency of Simple Cycle and Combined Cycles for Reciprocating Engines and CCGT




- The multi unit engine power plant has very high part load efficiency.

Reliability & Availability of Reciprocating Engines




As the Wärtsilä power plant consists of 3 power plants with each 16 Gas/HFO engines, it is unlikely that its available output will go below 1000 MW.

Wärtsilä single gas engine availability over 20 years life



The red dashed line show the levelized 20-year average availability of 93 %.


Wärtsilä Power Plant anticipated power production capability




The available output of the Wärtsilä power plant is above 1030 MW during 7,500 h/a. Based on the above the overall plant availability will be appr. 95 %

Why Should Engines be added as an alternative to GTs


Overnight capital costs (R/kW)




Heat Rate, kJ/kWh, avg




Water usage, l/MWh



CO2 emissions (kg/MWh)




Diesel Peaker Plant Comparison



*Diesel at zar 6/l.

Conclusion : Do not limit IRP to GTs , include ENGINES





WÄRTSILÄ